




АРМИРОВКА ДЪНО
BOTTOM REINFORCEMENT




РАЗРЕЗ В-В
SECTION В-В




ХОРИЗОНТАЛНА АРМИРОВКА СТЕНИ
WALLS - HORIZONTAL REINFORCEMENT



НИВО -0.30 - АРМИРОВКА
LEVEL -0.30 - REINFORCEMENT



ФИКСИРАНЕ НА ГОРНАТА АРМИРОВКА
FIXING UPPER REINFORCEMENT



Спецификация на армировката

7Дим.	№6.5	N10
kg	45	968
1013		
1013		

ЗАБЕЛЕЖКИ:

- Бетон клас В25–W0.4, за стоманобетон – (по БДС)
- Бетон клас В10 за подложен бетон – (по БДС)
- Армировка АI с Rs=225MPa (означена с φ) – (по БДС)
- Армировка АIII с Rs=375MPa (означена с N) – (по БДС)
- Сезиичност – VII см.
- Всички размери са в сантиметри.
Котире в метри.
- Прието допусъимо почвено натоварване Ro=0.20 MPa
- Кота ±0.00=150.00
- Мин. покритие на армировката – 3 см.

NOTES

- Concrete Class B25–W0.4 for reinforced concrete – (BSS)
- Concrete Class B10 for mass concrete – (BSS)
- Reinforcement AI с Rs=225MPa (indicate with φ) – (BSS)
- Reinforcement AIII с Rs=375MPa (indicate with N) – (BSS)
- Seismicity– VII grade
- All dimensions are in centimeters.
Elevations in metres.
- Ro=0.20 MPa
- Level ±0.00=150.00
- Min. reinforcement cover – 3 cm

Rev. E					
Rev. D					
Rev. C					
Rev. B					
Rev. A	__	2008			
REVISION	DATE	NAME	APPROVED	MODIFICATION	
ALL RIGHTS RESERVED ! This drawing and the information contained therein is the property of Joint Venture. No part of this drawing may be reproduced, stored in a retrieval system, or transmitted in any form, or by any means, electronic, mechanical, photocopying, recording or otherwise, without the prior permission of the copyright holder.					
EMPLOYER	MINISTRY OF ENVIRONMENT AND WATER Directorate "European Union Funds for Environment" ISPA Measure No 2002/BG/16/P/PE/018				
FINAL APPROVAL	DIWI Consult International GmbH LEADING PARTNER				
PROJECT	SHOUMEN WATER CYCLE IMPROVEMENTS - BULGARIA Lot No 1 : Network Design				
ОБЕКТ	ПОДОБРЕНИЕ НА ВОДНИЯ ЦИКЪЛ НА гр. ШУМЕН-БЪЛГАРИЯ Лот № 1 Проект на мрежата				
PART	SEWAGE PUMP STATION				
ЧАСТ	КАНАЛИЗАЦИОННА ПОМПЕНА СТАНЦИЯ				
DRAWING TITLE	SCHAFT - REINFORCEMENT				
СЪДЪРЖАНИЕ	ШАХТА - АРМИРОВКА				
TEAM LEADER РАКОВОДИТЕЛ	C. HAMILTON К. ХАМИЛТОН	COORDINATED СЪГЛАСУВАНИ	G. SUP. Г.З.	ARCHIVE АРХИВ	
TEAM MANAGER ПРОЕКТ МЕНИДЖЕР	R. KOTHE Р. КОТЕ	TECHN. ТЕХН.	EL ЕЛ	PART ЧАСТ	
DESIGNER ПРОЕКТАНТ	V. VASILEVA В. ВАСИЛЕВА	ARCH. АРХ.	SCADA КЛИВА	CONSTR. КОНСТР.	DD РП
DESIGNER ПРОЕКТАНТ				SCALE МАЩАБ	1 : 50
				DATE ДАТА	09.2012
				REVISION РЕВИЗИЯ	0
				DRAWING No ЧЕРТЕЖ No	DD / SH / D / 05 / 008