




Спесификация на армировката

?Диам.	⌀6.5	⌀8	N12	N14	N16	N20
kg	60	277	104	25	23	21
	337		174			
	511					

ЗАБЕЛЕЖКИ:

1. Бетон клас B25, за стоманобетон – (по БДС)
2. Бетон клас B10 за подложен бетон – (по БДС)
3. Армировка AI с Rs=225MPa (означена с ⌀) – (по БДС)
4. Армировка AIII с Rs=375MPa (означена с N) – (по БДС)
5. Сеизмичност – VII ст.
6. Всички размери са в сантиметри.
 Котите в метри.
7. Кота ±0,00=150.00
8. Мин. покритие на армировката
 за колони – 2,5 см.
 за греди – 2 см.
 за плочи – 1,5 см.

NOTES

1. Concrete Class B25 for reinforced concrete – (BSS)
2. Concrete Class B10 for mass concrete – (BSS)
3. Reinforcement AI с Rs=225MPa (indicate with ⌀) – (BSS)
4. Reinforcement AIII с Rs=375MPa (indicate with N) – (BSS)
5. Seismicity– VII grade
6. All dimensions are in centimeters.
 Elevations in metres.
7. Level ±0,00=150.00
8. Min. reinforcement cover
 for columns – 2,5 см.
 for beams – 2 см.
 for slabs – 1,5 см.

REVISION	DATE	NAME	APPROVED	MODIFICATION
Rev. E				
Rev. D				
Rev. C				
Rev. B				
Rev. A	__.__.2008	_____	_____	_____

ALL RIGHTS RESERVED ! This drawing and the information contained therein is the property of Joint Venture. No part of this drawing may be reproduced, stored in a retrieval system, or transmitted in any form, or by any means, electronic, mechanical, photocopying, recording or otherwise, without the prior permission of the copyright holder.

EMPLOYER

MINISTRY OF ENVIROMENT AND WATER
Directorate "European Union Funds for Enviroment"
ISPA Measure No 2002/BG/16/P/PE/018

FINAL APPROVEL

CONSULTANT - JOINT VENTURE

DIWI Consult International GmbH
LEADING PARTNER

PROJECT ОБЕКТ	SHOUMEN WATER CYCLE IMPROVEMENTS - BULGARIA Lot No 1 : Network Design ПОДОБРЕНИЕ НА ВОДНИЯ ЦИКЪЛ НА гр. ШУМЕН-БЪЛГАРИЯ Лот № 1 Проект на мрежата			
PART ЧАСТ	SEWAGE PUMP STATION КАНАЛИЗАЦИОННА ПОМПЕНА СТАНЦИЯ			
DRAWING TITLE СЪДЪРЖАНИЕ	LEVEL +4.00 BEAMS НИВО +4.00 ГРЕДИ		ARCHIVE АРХИВ	
			PART ЧАСТ	CONSTR. КОНСТР.

TEAM LEADER РЪКОВОДИТЕЛ ЕКИП	C. HAMILTON К. ХАМИЛТОН		COORDINATED СЪГЛАСУВАЛИ	G. SUP. ГАЗ.	PHASE ФАЗА	DD РП
TASK MANAGER ПРОЕКТ МЕНИДЖЕР	R. KOTHE Р. КОТЕ		TECHN. ТЕХН.	EL ЕЛ.	SCALE МАЩАБ	1 : 50
DESIGNER ПРОЕКТАНТ	V. VASILEVA В. ВАСИЛЕВА		ARCH. АРХ.	SCADA КИПиА	DATE ДАТА	09.2012
DESIGNER ПРОЕКТАНТ			CONSTR. КОНСТР.	HV ОВИ	REVISION РЕВИЗИЯ	0
			VP ВП	WSSS ВК	DRAWING No ЧЕРТЕЖ No	DD / SH / D / 05 / 006